

## Connecticut Construction Industries Association, Inc.

### CONN-OSHA Violations of Construction Standards in Connecticut July 1, 2007 through December 31, 2007

The following is the information requested by the CCIA from CONN-OSHA regarding violations of the construction standards (1926) in the Public Sector in Connecticut for the time period July 1, 2007 through December 31, 2007.

Standard	Explanation	Total Violations	Fines Imposed	Fines Collected
31-372-107 1926.21(b)(2)	The employer shall instruct each employee in the recognition and avoidance of unsafe conditions and the regulations applicable to his work environment to control or eliminate any hazards or other exposure to illness or injury.	1	\$360.00	\$180.00
31-372-107 1926.202	The employer shall ensure that a proper work zone is created to protect employees from vehicular traffic while performing road traffic.	1	\$70.00	\$35.00
31-372-107 1926.501(b)(10)	The employer must ensure that employees performing roofing work on low-slope roofs use fall protection.	1	\$210.00	\$100.00
31-372-107 1926.651(c)(2)	Means of egress from trench excavations. A stairway, ladder, ramp or other safe means of egress shall be located in trench excavations that are 4 feet (1.22 m) or more in depth so as to require no more than 25 feet (7.62 m) of lateral travel for employees.	1	\$360.00	\$180.00
31-372-107 1926.651(k)(1)	Daily inspections of excavations, the adjacent areas, and protective systems shall be made by a competent person for evidence of a situation that could result in possible cave-ins, indications of failure of protective systems, hazardous atmospheres, or other hazardous conditions.	1	\$360.00	\$180.00

31-372-107 1926.651(k)(2)	Where the competent person finds evidence of a situation that could result in a possible cave-in, indications of failure of protective systems, hazardous atmospheres, or other hazardous conditions, exposed employees shall be removed from the hazardous area until the necessary precautions have been taken to ensure their safety.	1	\$360.00	\$180.00
31-372-107 1926.652(a)(1)	Each employee in an excavation in excess of 5 feet deep must be protected from cave-ins by an adequate protective system.	1	\$360.00	\$180.00
<b>TOTAL</b>		<u>7</u>	<u>\$2080.00</u>	<u>\$1035.00</u>